

MOBILE HOME AND PORTABLE TOILET CARTRIDGE DUMP FACILITY – PUB40

Background

Mobile home and portable toilet waste includes waste from mobile homes and portable cartridge type toilets for caravans.

Mobile and portable toilet cartridge waste has an organic content many times that of normal domestic wastewater, and may contain various treatment chemicals. It is therefore an industrial waste whose discharge to sewer in commercial quantities must be controlled through the Water Corporation's industrial waste permitting system.

Discharge from portable toilet waste domestic and international aircraft, trains, marine craft, ferries, building site toilets and passenger road coaches is covered in the information brochure – Discharge of portable toilet waste – PUB 26

Requirements

All portable toilet waste that is to be discharged to sewer must be disposed of at designated mobile home & portable toilet cartridge dump facilities which could be located at Caravan Parks, Roadside Stops, Showgrounds and other locations.

An application to discharge industrial waste must be submitted for assessment prior to the installation of any proposed discharge point.

All designated discharge points must have a permit held by the party that owns, operates and provides the facility. In the case of caravan parks that may have several dump points, each one is designated separately on a single permit.

Refer to typical drawing HX33-018-80 Mobile Homes & Cartridge Dump Facility available for download from the Water Corporation website.


Mobile home and portable toilet cartridge dump facilities are to be constructed with a bunded area to prevent any spillage to the environment. The minimum outlet is to 150mm (LIT) connected to 100mm gully. Refer to typical drawing HX33-18-80.

A hinged lockable lid is to be fitted and the key kept with the person responsible where the mobile home and portable toilet cartridge dump facility is located. The mobile home and portable toilet cartridge dump facility must be secured to prevent any illegal dumping, with a key available for customers wishing to use the facility. When the key is given out to the customer, details are to be recorded in the dump point logbook. (IWForm 1-8-3).

A hose tap with trigger action nozzle is to be located within 2 metres of the mobile home and portable toilet cartridge dump facility. The hose tap must comply with AS/NZS 3500.1:2003 and be fitted with an appropriate testable backflow prevention device.

This installation is deemed to be a high hazard for backflow prevention within the property therefore a boundary containment device is required to comply with Water Corporation Backflow Prevention Policy. <http://www.watercorporation.com.au/B/backflow.cfm>

INDUSTRIAL WASTE INFORMATION BROCHURE



The mobile home and portable toilet cartridge dump facility is to be protected from vehicular damage by the installation of a 100mm bollard on each corner.

Biodegradable and environmentally safe toilet additives should always be encouraged. Formaldehyde based additives should be discouraged.

A sign is to be located adjacent to the mobile home and portable toilet cartridge dump facility with a minimum size of 600mm x 400mm. The business owner is responsible to have the sign made and installed.



Toilet Disposal Facility

This dump point is solely for the use of Mobile Homes and Cartridge type toilets. All other liquid waste is prohibited by law.
Keys are available at **Insert location**

Accepting Waste from Third Parties

Accepting wastes from tankered septic effluent contractors is not allowed.

More Information?

The current version of this information sheet is shown on the Water Corporation Internet site http://www.watercorporation.com.au/l/industrialwaste_index.cfm. Further information on the issue detailed on this sheet can be obtained by phoning 13 13 95, or visit your nearest Water Corporation office.

13 13 75 Faults, Emergencies & Security
13 13 95 Technical Enquiries
13 13 85 General Enquiries

Printed on environmentally friendly paper



www.watercorporation.com.au