

Approval certificate

Trade waste pre-treatment product

Applicant: Halgan Pty Ltd
Postal address: 10 Davis Road, Wetherill Park, NSW 2164

Attention: Joel Brooks
Web: www.halgan.com.au
Email: info@halgan.com.au

Manufacturer: Halgan Pty Ltd
Address: 10 Davis Road, Wetherill Park, NSW 2164

Product description

Halgan Pty Ltd provides a plaster and clay trap for industrial and commercial drainage systems, such as education, medical and art projects, etc.

The product is manufactured from 304 stainless steel.

The approval certificate applies to the pre-treatment products:

Approval Number	Model	Volume	Body			Inlet Size	Outlet Size
			L	W	H		
AN-083-01	PT/SS/5	50 L	363 mm	363 mm	401 mm	50 mm	50 mm
AN-083-02	CPT/SS/5	50 L	595 mm	304 mm	422 mm	50 mm	50 mm

Special conditions of approval

1. The product shall be *supplied* with manufacturer's installation instructions and recommended procedures for operation and maintenance.
2. The product shall be *installed* by a licensed plumber according to the *Plumbing Standards* and *serviced* strictly in accordance with the manufacturer's written instructions, with particular emphasis on the following:
 - a. *Installation Requirements – Plaster Trap & Clay Plaster Trap* (dated 09 Jan 2025)
3. The product shall be *maintained* to ensure the ongoing reliability of the product and that discharges to sewer comply with Water Corporation's *Acceptance Criteria for Trade Waste*.
4. The product chosen must be suitably sized to avoid surge conditions.
5. Water Corporation must be notified within fourteen (14) days upon installation of the product.
6. Clear access for the purposes of maintenance or servicing of the pre-treatment device must be maintained at all times.
7. This approval certificate is not an endorsement of the product by Water Corporation, and no claim shall be made in advertising, promotion or other manner to the effect.
8. Water Corporation accepts no responsibility for the effective operation, performance or efficiency of the product. This approval is not an engineering approval or structural endorsement.
9. The proponent of the approved product must formally seek a request for re-approval of the product no later than three (3) months before the assigned **Validity Period** has expired from the **Date Issued** of this approval certificate.
10. Water Corporation reserves the right to vary any requirements at any time. Any application of this condition normally occurs after consultation with the manufacturer, supplier and end business user connected to Water Corporation's sewer.
11. Water Corporation shall be notified in writing if the pre-treatment device is withdrawn from sale.
12. The proponent of the approved product accepts that the information provided in this document shall be made publicly available.

Approval certificate

Trade waste pre-treatment product

General conditions of approval

Approval shall be **suspended** where any of the following conditions are not met:

1. If there is a breach of the Special Conditions.
2. The assigned **Validity Period** has expired from the **Date Issued** of this approval certificate.
3. The product shall be manufactured in accordance with Water Corporation's requirements at the time of approval.
4. The product shall be manufactured to comply according to the details noted in the drawings reference below, in addition to any further details provided by the proponent when seeking this approval.
5. The product supplied for use in Water Corporation's area of operations shall comply with the requirements shown on this approval certificate. Sizes, classes, lengths or other product variables which are available with the product, but which are not approved as listed on this approval certificate shall not be offered by the supplier for use in Water Corporation's area of operations.
6. All discharges to sewer associated with this product must not exceed Water Corporation's *Trade Waste Acceptance Criteria*. Where the discharge *has* or is *likely* to exceed the *Trade Waste Acceptance Criteria* then the Corporation may direct a *specific* or *ongoing* maintenance requirement to be followed.
7. Prior to any business (which is connected to Water Corporation's sewer) installing this product the business must apply to Water Corporation for a *Trade Waste Permit* for approval to discharge.
8. If this certificate has been issued to the manufacturer of this product, then it is the responsibility of the manufacturer to ensure all current and future suppliers / vendors of this product are provided a copy of this approval certificate.

Approval shall be **reviewed** where any of the following conditions occur:

1. The product is manufactured with either different materials, methods of manufacture, location of manufacture, source of raw materials, component subcontractors or models to that at the time of approval.
2. The ownership of the primary manufacturer or any subcontractors is varied from that at time of approval.
3. The standards and/or specifications to which the product was required to comply with at the time of approval have been amended or revised. It is the responsibility of the proponent to immediately advise Water Corporation of any changes to the proponent's drawings and installation, operation and maintenance manuals made at the time of approval.
4. The product has been found to sustain damage or provide unsatisfactory performance on a number of occasions considered excessive by Water Corporation, when handled, stored, assembled or installed in accordance with the supplier's or manufacturer's written instructions.

Approved drawing(s): Halgan Plaster Trap Detail (PT/SS/5, Rev A dated 22 Feb 2021)
Halgan Clay Plaster Trap Detail (CPT/SS/5, Rev A dated 22 Feb 2021)

Authorising person: Stephen Jerkovic (Specialist – Compliance Operations)

Date issued 20 January 2025

Validity period: Five (5) years